LICENCE NUMBER 5567 Licencing Period 2020 - 2021



	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 3)										
	SAMPLE	DATE		BOD	Nitrate/Nitrate	Ammonia as N	рН	Phosphorus Total (mg/L)	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease
Taken	Received	Reviewed by	Published	(mg/L)	(mg N/L)	(mg N/L)	pH units	(mg/L)	(mg/L)	(mg/L)	(mg/L)
07/07/2020	22/07/2020	JG	10/08/200	90	0.02	34.41	7.52	4.972	37	30	13
										ļ	
										I	
										ļ	
										1	
	Lowest Sam	nle Value		90	0.02	34.41	7.52	4.972	37	30	13
Lowest Sample Value Mean Sample Value											
	Highest Sample Value										
	100 Percentile Limit			30	N/A	N/A	5.5 - 9.5	N/A	N/A	45	10
	Exceed			30 Y	N/A	N/A	N	N/A	N/A	Y	Y
					11// 1			1 1/7 1	11// 1		•



LICENCE NUMBER 5567 Licencing Period 2020 - 2021

EFF	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2) Discharge Monitoring Continuous										
	SAMPLE	E DATE		Start	End	Total					
Taken	Received	Reviewed by	Published	KL	KL	KL					
07/07/2020	22/07/2020	JG	10/08/200		48693						

EXCE	EXCEEDANCE REPORT										
SAMPLE DAT	E										
Taken	Parameter	Comment									

LICENCE NUMBER 5567 Licencing Period 2019 - 2020



		EFFI	LUENT	MONITOR		TLY TEST	RESULTS	(POINT 3)			
Taken	SAMPLE		Dubliched	BOD	Nitrate/Nitrate		pH	Phosphorus Total (mg/L)	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease (mg/L)
		Reviewed by	Published	(mg/L)	(mg N/L)	(mg N/L)	pH units	(mg/L)	(mg/L)	(mg/L)	
14/05/2019	15/05/2019	JG		13	0.02	21.01	1.2	4.528	31.80	50	33
26/11/2019 11/02/2020	26/11/2019 12/02/2020	JG JG		8 159	4 0.02	30.73 37.42	7.23 6.83	5.980 5.736	31.70 43.60	30 114	22 0
				8.00							
-	Lowest Sample Value				.02	21.01	7.2	4.53	31.70	30.00	0.00
	Mean Sample Value				1.35	29.72	7.23	5.41	35.70	64.67	18.33
Highest Samp	Highest Sample Value				4.00	37.42	6.83	5.98	43.60	114.00	33.00
100 Percentile	100 Percentile Limit				N/A	N/A	5.5 – 9.5	N/A	N/A	45	10
Exceedance	Exceedance				N/A	N/A	Y	N/A	N/A	Y	Y



LICENCE NUMBER 5567 Licencing Period 2019 - 2020

EF	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2) Discharge Monitoring Continuous										
	SAMPL	E DATE		Start	End	Total					
Taken	Received	Reviewed by	Published	KL	KL	KL					
		JG									
		JG									

EXC	EXCEEDANCE REPORT									
SAMPLE DAT	Ē									
Taken	Parameter	Comment								

LICENCE NUMBER 5567 Licencing Period 2018 - 2019



		EFFI	UENT	MONITOR	ING QUAR	TLY TEST	RESULTS	(POINT 3)			
	SAMPLE	DATE		BOD	Nitrate/Nitrate	Ammonia as N	рН	Phosphorus Total	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease
Taken	Received	Reviewed by	Published	(mg/L)	(mg N/L)	(mg N/L)	pH units	(mg/L)	(mg/L)	(mg/L)	(mg/L)
02/07/2018	03/07/2018	JG		16	0.09	46.01	7.75	7.46	47	40	27
16/10/2018	17/01/2018	JG		12	5.20	22.61	7.69	7.59	24	214	10
19/02/2019	20/02/2019	JG		17	2.08	21.06	7.73	5.42	28.4	20	7
04/03/2019	05/03/2019	JG		13	0.05	15.32	7.62	6.75	25.0	20	8
Lowest Sampl	e Value			12.00	0.05	15.32	7.62	5.42	24.00	20.00	
Mean Sample Value				14.50	1.86	26.25	7.70	6.81	31.10	73.50	
Highest Sample Value				17.00	5.20	46.01	7.75	7.59	47.00	214.00	
	100 Percentile Limit				N/A	N/A	5.5 – 9.5	N/A	N/A	45	10
Exceedance				30 N	N/A	N/A	N	N/A	N/A	Y	
	Exceedance										



LICENCE NUMBER 5567 Licencing Period 2018 - 2019

EF	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2) Discharge Monitoring Continuous										
	SAMPL	E DATE		Start	End	Total					
Taken	Received	Reviewed by	Published	KL	KL	KL					

EXC	EXCEEDANCE REPORT									
SAMPLE DAT	E									
Taken	Parameter	Comment								

LICENCE NUMBER 5567 Licencing Period 2017 - 2018



		EFFI	LUENT	MONITOR	ING QUAR	TLY TEST	RESULTS	(POINT 3)			
	SAMPLE			BOD		Ammonia as N	рН	Phosphorus Total	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease
Taken	Received	Reviewed by	Published	(mg/L)	(mg N/L)	(mg N/L)	pH units	(mg/L)	(mg/L)	(mg/L)	(mg/L)
02/07/2018	03/07/2018	JG		87	0.1	28.2	7.65	6.29	32	20	16
16/10/2018	17/10/2018	JG		49	0.1	27.3	7.6	5.7	35	20	17
19/02/2019	20/02/2019	JG		17	20.8	21.06	7.73	5.42	28.4	20	7
01/03/2019	05/03/2019	JG		13	0.05	15.32	7.62	6.75	25	20	
	Lowest San	nple Value		13.00	0.05	15.32	7.60	5.42	25.00	20.00	
	Mean Sample Value			41.50	0.58	22.97	7.65	6.04	30.10	20.00	
	Highest Sample Value			87.00	20.8	28.20	7.73	6.75	35.00	20.00	
	100 Percer	-		30	N/A	N/A	5.59.5	N/A	N/A	45	10
	Exceed	lance		Y	N/A	N/A	Ν	N/A	N/A	N	



LICENCE NUMBER 5567 Licencing Period 2017 - 2018

EFF	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2) Discharge Monitoring Continuous										
	SAMPLE	DATE		Start	End	Total					
Taken	Received	Reviewed by	Published	KL	KL	KL					
	ļ ļ										

EXC	EXCEEDANCE REPORT								
SAMPLE DAT	Ē								
Taken	Parameter	Comment							

LICENCE NUMBER 5567 Licencing Period 2017 - 2018



	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 3)										
	SAMPLE	DATE		BOD	Nitrate/Nitrate	Ammonia as N	рН	Phosphorus Total	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease
Taken	Received	Reviewed by	Published	(mg/L)	(mg N/L)	(mg N/L)	pH units	(mg/L)	(mg/L)	(mg/L)	(mg/L)
16/06/2016	17/06/2016	JG		31	14	18	7.3	5.8	23	35	10
16/08/2016	17/08/2016	JG		125	.03	37	7.4	6.81	46	48	
01/03/2017	02/03/2017	JG		10	27.5	21.4	7.25	7.46	24	155	
11/04/2017	13/04/2017	JG		43	0.1	24.7	7.49	5	30	20	13
Lowest Sample Value				10.00	0.10	18.00	7.25	5.00	23.00	15.00	
Mean Sample Value				52.25	10.48	25.28	7.36	6.27	30.75	29.50	
Highest Sample Value				125.00	27.50	37.00	7.49	7.46	46.00	48.00	
100 Percentile Limit				30	N/A	N/A	5.5 - 9.5	N/A	N/A	45	10
Exceedance			Y	N/A	N/A	N	N/A	N/A	Y	Y	



LICENCE NUMBER 5567 Licencing Period 2017 - 2018

EFF	EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2) Discharge Monitoring Continuous									
	SAMPL	E DATE		Start	End	Total				
Taken	Received	Reviewed by	Published	KL	KL	KL				
12/03/2017					4046					

EXC	EXCEEDANCE REPORT						
SAMPLE DATE							
Taken	Parameter	Comment					