


NOTE:

- 1. ALL TAPPINGS ARE TO BE CARRIED OUT BY COUCIL.
- IF METER IS TO BE PLACED BELOW GROUND LEVEL THEN THE INSTALLATION IS TO COMPLY WITH AS 35000.1 AND BE APPROVED BY THE ENGINEER.
- 3. ROAD OPENING AND A TRAFFIC PLAN IS TO BE OBTAINED/ PRESENTED TO COUNCIL BEFORE ANY WORK COMMENCESON SITE.
- 4. MINIMUM COVER IN PUBLIC AREAS TO BE 450 MM.
- 5. PLUMBING TO BE SUPPLIED BY OWNERS LICENCED PLUMBERS.
- 6. ALL ROAD CROSSINGS SHALL BE SLEEVED IN ACCORDANCE WITH COUNCIL SPECIFICATIONS.



WENTWORTH SHIRE COUNCIL

WORTH 亚 DRIVE

STANDARD RURAL UNFILTERED WATER CONNECTION

DATE: July 2004

DRAWING NUMBER:

127-103