



NOTE:

1. 20 mm coper or 25 class 12 black poly to be used for main to meter single property connection.
2. Min 25 mm copper or 32 class 12 black poly / P.E. for connection between main and 20 X 20 X 25 tee.
3. Single connection 20mm tapping, dual connection 25mm.
4. Single tapping dual connection configuration service max 2 properties.
5. All road crossing in 90 mm dia conduit storm water pipe.
6. Road crossing to be marked " W " on kerbs and gutter face.
7. Road crossings min 450 mm depth, top of conduct.
8. Road permit required any work in road reserve.