

# WENTWORTH SHIRE COUNCIL EAST WENTWORTH OXIDATION PONDS

## LICENCE NUMBER 3342

Licencing Period 2022 - 2023

EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 3)										
SAMPLE DATE			Ammonia as N	Biochemical Oxygen Demand (BOD)	Nitrogen Oxides	pH	Phosphorus, Total	Total Kjeldahl Nitrogen	Total Suspended Solids	Oil & Grease
Taken	Reviewed By	Published	(mg N/L)	(mg/L)	meters	pH Units	(mg/L)	(mg/L)	(mg/L)	(mg/L)
27/06/2022	JG	JJ	51	259	0.16	7.13	7.9	61	250	57
13/12/2022	JG	JJ	5.3	50	0.06	8.61	5.8	22	248	35
18/01/2023	JG	JJ	1.6	24	0.02	9.51	3.1	18	152	5
4/04/2023	JG	JJ	28.2	110	0.032	6.27	4.6	40.8	102	18
Total			86.1	443	0.272	31.52	21.4	141.8	752	115
Mean Sample Value			21.53	110.75	0.07	7.88	5.35	35.45	188.00	28.75
Highest Sample Value			51.00	259.00	0.16	9.51	7.90	61.00	250.00	57.00
Lowest Sample Value			1.60	24.00	0.02	6.27	3.10	18.00	102.00	5.00

# WENTWORTH SHIRE COUNCIL EAST WENTWORTH OXIDATION PONDS

## LICENCE NUMBER 3342

*Licencing Period 2022 - 2023*

EFFLUENT MONITORING QUARTLY TEST RESULTS (POINT 2)											
SAMPLE DATE			BOD	TSS	pH	*Oil & Grease	Nitrate	Amonia as N	Total Kjeldahl Nitorgen	Total Suspended Solids	
Taken	Reviewed by	Published	(mg/L)	(mg/L)	pH units	(mg/L)	(mg N/L)	(mg N/L)	(mg/L)	(mg/L)	
27/06/2022			Flow Meter Failed- No Data Recorded								
13/12/2022			Flow Meter Failed- No Data Recorded								
18/01/2023			Flow Meter Failed- No Data Recorded								
4/04/2023			Flow Meter Failed- No Data Recorded								
Total											
Mean Sample Value											
Highest Sample Value											
Lowest Sample Value											

